



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

C R WATER TREATMENT
POST OFFICE BOX 717
LAKEHEAD, CA 96051

Sampled By: ERNIE GOFF
Client Contact: ERNIE GOFF
Phone: (530) 238-2336
Fax: 238-2336

Lab No: 18G0598
Reported: 07/13/18
System Number:
Regulator:
P.O. #

BACTERIA TESTING 7693 LINDA

Coliform Analysis Report

Standard Total Coliform & E.coli

Analysis	Result	Chlorine (mg/l)	Sample Receipt Temp (C)*	Set Up	Read Out	Method
7693 LINDA (18G0598-01) Grab Sampled: 07/11/18 16:00 Received: 07/12/18 13:35						

Total Coliforms	Absent		25.4	07/12/18 15:15	07/13/18 09:15	Colilert
E. Coli	Absent		25.4			

Notes and Definitions

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of **Fecal coliforms** and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

* **Sample Receipt Temp:** According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Approved By

Basic Laboratory Inc

California ELAP Cert #1677 and #2718